

# Annexure C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No

Dated: 30/12/2025

It is certified that an inspection team headed by Ravi Prakash, Executive Engineer

(Name of Officers with designation) from P.H. Division Bhabua, PHED

inspected the Paras Children Academy, Lalapur, Kudra, Kaimur

(Name & Address of the school) on 29/12/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 92/2025 dated 26/12/2025

of D.L.W.T.L., P.H. Div., Bhabua (PHED Lab) certified that

the Paras Children Academy (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till June-2026

Signature with Seal:

Name

Designation

Name & Address of the Officer, Department

Ravi Prakash

Executive Engineer

P.H. Division Bhabua, P.H.E.D

To

Paras Children Academy  
Lalapur, Kudra, Bhabua Kaimur  
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Government of Bihar  
Public Health Engineering Department  
District Level Water Testing Laboratory - Public Health Division - Bhadrachal  
Drinking Water Quality Test Monitoring Report

Report No. - 92/2025

Zone - Patna

District - Kaimur (Bhadrachal)

Issue Date - 26-12-2025

Sl. No.	Block	Panchayat / Town	Village / Locality	Habitation / Ward No.	Source of sample	Sample received date	Final Tested date	pH	Turb	EC	TDS	Tested Parameter in mg/L. (Except pH)										Remarks
												T. Hard	Ca	Mg	T. Alka	Cl	NO <sub>3</sub>	F	T. Coll			
1	PARAS CHILDREN ACADEMY, TALAPUR KUDRA, KAIMIUR (BHABUA)	NO FILTER WATER	22-12-25	26-12-25	8.72	0.40	675.38	439.00	136.00	48.00	3.84	210.00	22.00	80L	0.15	A						
2	PARAS CHILDREN ACADEMY, TALAPUR KUDRA, KAIMIUR (BHABUA)	BOWELL WATER	22-12-25	26-12-25	8.14	0.47	955.38	621.00	156.00	32.00	18.24	312.00	37.00	80L	0.22	A						
Desirable Limit								6.5-8.5	1.0	-	500	200	75	30	200	250	45	1				
Permissible limit in absence of alternate source (IS 10500-2012) 2nd revision								NR	5.0	-	2000	600	200	100	600	1000	NR	1.5				

Note :- All the parameter tested in this laboratory are found within the maximum permissible limit.

\* Above given details of Water Sample collected and submitted in laboratory for water quality test. Sample give R.RAY, SCHOOL STAFF

Ashok Kumar  
26/12/2025  
Chemist/Asst. Chemist  
DLWT- Lab, P.H. Division,  
Kaimiur (Bhabua)

Executive Engineer  
Public Health Division  
Kaimiur (Bhabua)

\* BDL = Below Detection Limit  
Page No. - 92

\* NI = Not Test

\* A = Absent

\* P = Present